

- 1. USE LYLE SIGN, "NO PARKING FIRE LANE, LR7-22 OR APPROVED EQUAL. SIGN MUST BE A MINIMUM OF 12" X 18", ALUMINUM PLATE, .080 MIN. THICKNESS, HIGH INTENSITY SHEETING, INSTALLED AT A HEIGHT 5' ABOVE GROUND, WITH RED LETTERING ON WHITE BACKGROUND (STANDARD).
- 2. THE SIGN SUPPORTS WILL BE A U POST, PAINTED GREEN. THE MATERIALS AND INSTALLATION REQUIREMENTS ARE PER DETAIL STRT—21 UNDER THE "POSTS" SECTION.
- 3. THE SUPPORTING POSTS SHALL BE SET BACK A MINIMUM OF 12" BUT NOT MORE THAN 36" FROM THE CURB ON BOTH SIDES OF THE FIRE LANE/PRIVATE DRIVE.
- 4. ALL SIGNS SHALL FACE THE
 DIRECTION OF TRAVEL AND BE
 INSTALLED ACCORDING TO THE
 LOCATIONS IDENTIFIED BY THE CITY
 ON THE APPROVED SITE PLAN,
 AND ONSTIE FOR THE DEVELOPMENT.
- 5. A FIRE LANE SHALL BE REQUIRED IN FRONT OF FIRE DEPARTMENT CONNECTIONS EXTENDING 5 FEET ON EACH SIDE AND ALONG ALL AREAS DESIGNATED BY THE FIRE OFFICIAL.
- 6. ANY DEVIATION FROM THE ABOVE REQUIREMENTS SHALL BE SUBMITTED IN WRITING, WITH A REVISED SITE PLAN, FOR PRIOR APPROVAL BY THE FIRE OFFICIAL.



STANDARD DETAILS

REQUIREMENT FOR FIRE LANE SIGNAGE ON PRIVATE DRIVES, EMERGENCY ACCESS DRIVES, AND FIRE LANES

CITY OF PLYMOUTH

PUBLISHED 3-25

CITY PL. NO. STRT-27 REVISED 1-20