



NOTE:

1. SELECT GRANULAR REQUIRED FOR ALL BEDDING
2. ALL VERTICAL BENDS SHALL BE TIED WITH SS RODDING. 2 RODS CONNECTING EACH JOINT 180° APART.
3. TRACER WIRE TO BE RUN WITH OFFSET PVC PIPE. (IF EXISTING WM IS CIP OR DIP, PINCH EXPOSED COPPER TRACER WIRE BETWEEN DOUBLE NUT ON EXISTING SIDES)
4. MEGALUGS MANUFACTURED BY EBAA IRON, SIGMA, SIP OR APPROVED EQUAL SHALL BE USED AT ALL MECHANICAL JOINTS
5. ALL BOLTS, T-BOLTS, NUTS AND RODDING INSTALLED BELOW GRADE SHALL BE ASTM F593 TYPE 304 STAINLESS STEEL
6. ADDITIONAL RODDING AND MEGALUGS MAY BE REQUIRED BY ENGINEER.



STANDARD DETAILS
VERTICAL OFFSET DETAIL
CITY OF PLYMOUTH

PUBLISHED
3-25

CITY PL. NO.
W-8
REVISED 1-24